

Third Party Interconnection battery acceptance

Type: Relay

Date: 07/18/16

Rev 2

Name of Customer: Humboldt Bay MWD

JO#: 8068216

Distribution engineer or PM: Martha Baeli

Reviewed by: Radai Mashriqi

Per Appendix B of PG&E Greenbook

(See attachment 4; last 2 pages of below link)

http://www.pge.com/includes/docs/pdfs/mybusiness/customerservice/otherrequests/newconstruction/greenbook/greenbook_manual.pdf#Appendix_B

The below items per Appendix B of PG&E Greenbook has been accepted by Radai Mashriqi

Item 1: Type of Utility Grade Battery – Accepted

Item 2. Detailed Load Information – Accepted

Item 3. Battery & Charger Sizing Calculations – Accepted

Item 4. Proof of 3hr-Discharge Testing (after install) – Accepted

Item 5. Maintenance Procedures – Accepted

Item 6. Monitoring of Minimum Battery Voltage – Accepted

(ensure battery DC low voltage is monitored as this will be verified during the Pre-Parallel inspection).

Thank you,

Thanks,

Radai Mashriqi

Substation Project Engineering

850 Stillwater rd

West Sacramento, CA 95691

916 760 3349