

## SEL Relay Settings Calculation for 1 MW Generator GEN 2 BU

SEL-700GT+ **Backup**, Part No: SEL- 0700GT1A2X9X75850330

The following procedures guide the reader through the process of setting the SEL-700G based upon industry standards and the SEL instruction manual.

### Configuration Summary

<b>Part Number</b>	0700GT1A2X9X75850330	<a href="#">Map</a>
<b>Key Code</b>	2037	
<b>Model</b>	700GT+ Model, Intertie and Generator Protection, Auto Synchronizer	
<b>SELECT Power Supply with I/O Option Slot A</b>	Power Supply 110–250 Vdc, 110–240 Vac, 50/60 Hz (SELECT PSIO / 2 DI / 3 DO); 125 Vdc/Vac Digital Input	
<b>SELECT Processor Board Option Slot B</b>	Processor Board (SELECT CPU/COM); All Slot B options include EIA-232 Front, IRIG-B, Fiber Optic Serial Multimode ST, SEL ASCII, Compressed ASCII, Fast Meter, Fast Operate, Fast Message, MIRRORRED BITS, and Modbus RTU	
<b>SELECT Ethernet/Rear Serial Options Slot B</b>	Ethernet/Rear Serial Options; Single 10/100Base-T Ethernet, EIA-485 Rear	
<b>SELECT Protocols Slot B</b>	Protocols; Standard plus DNP3 plus IEC 61850 (requires Ethernet)	
<b>SELECT I/O Card Option Slot C</b>	8 Digital Output (SELECT 8 DO); Electromechanical DO	
<b>SELECT I/O Card Option Slot D</b>	10 RTD Input (SELECT 10 RTD)	
<b>SELECT I/O Card Option Slot E</b>	3-Phase AC Current Input / 3-Phase AC Voltage (300 Vac) Input and Vsync Input (SELECT 3 ACI / 4 AVI); 5 Amp Phase	
<b>SELECT I/O Card Option Slot Z</b>	3-Phase AC Current Input / Neutral AC Current Input / 3-Phase AC Voltage (300 Vac) (SELECT 4 ACI / 3 AVI); 5 Amp Phase, 5 Amp Neutral	
<b>Conformal Coat</b>	None	

## Calculation of the Protection Settings for G1 - SEL-700G

### 1. General Data

Generator X side Current Transformer Ratio Calculations

$$CTR_X := \frac{200}{5}$$

$$CTR_X = 40$$

Generator Potential Transformer Ratio Calculations

$$PTR_X := \frac{4200}{120}$$

$$PTR_X = 35$$

Generator Nominal Secondary Voltage Calculations

$$DELTA\_X = DELTA$$

Bus Y side Current Transformer Ratio Calculations

$$CTR_Y := \frac{300}{5}$$

$$CTR_Y = 60$$

Bus Potential Transformer Ratio Calculations

$$PTR_Y := \frac{4200}{120}$$

$$PTR_Y = 35$$

Generator and Bus Nominal Secondary Voltage Calculations

$$VNOM := \frac{4160}{PTR_X}$$

$$VNOM = 118.9$$

$$VNOM := \frac{4160}{PTR_Y}$$

$$VNOM = 118.9$$

Relay setting is primary L-L voltage [kV]

$$VNOM\_X := 4.16$$

Relay setting is primary L-L voltage [kV]

$$VNOM\_Y := 4.16$$

Generator Name Plate Ratings

Nominal Frequency = 60Hz

$$FNOM := 60$$

Generator Capacity

$$Gen\_VA := 1176000$$

Generator Voltage

$$Gen\_V := 4160$$

Generator Power Factor

$$Gen\_pf := 0.85$$

Generator Synchronous Reactance  $X_d$  [p.u.]

$$X_d := 1.75 \text{ [p.u.]}$$

Generator Transient Reactance  $X_d'$  [p.u.]

$$X_{d\_trans} := 0.33 \text{ [p.u.]}$$

Generator Subtransient Reactance  $X_d''$  [p.u.]

$$X_{d\_subtrans} := 0.198 \text{ [p.u.]}$$

Conversion of Generator Nameplate Reactance to secondary value calculations

Primary

$$V_{base} := 4160$$

$$MVA_{base} := 1176000$$

$$I_{base} := \frac{MVA_{base}}{(\sqrt{3} \cdot V_{base})}$$

$$Z_{base} := \frac{V_{base}^2}{MVA_{base}}$$

$$I_{base} = 163.212$$

$$Z_{base} = 14.716$$

$$X_{d_{sec}} := X_d \cdot Z_{base} \cdot \frac{CTR_X}{PTR_X}$$

$$X_{d'_{sec}} := X_{d_{trans}} \cdot Z_{base} \cdot \frac{CTR_X}{PTR_X}$$

$$X_{d''_{sec}} := X_{d_{subtrans}} \cdot Z_{base} \cdot \frac{CTR_X}{PTR_X}$$

$$X_{d_{sec}} = 29.431 \text{ Ohms}$$

$$X_{d'_{sec}} = 5.55 \text{ Ohms}$$

$$X_{d''_{sec}} = 3.33 \text{ Ohms}$$

## 2. Calculate Generator secondary nominal current

$$I_{NOM} := \frac{\left( \frac{Gen\_VA}{\sqrt{3} \cdot Gen\_V} \right)}{CTR_X}$$

$$I_{NOM} = 4.08$$

## 2. Calculate Bus secondary nominal current

$$I_{NOMY} := \frac{\left( \frac{Gen\_VA}{\sqrt{3} \cdot Gen\_V} \right)}{CTR_Y}$$

$$I_{NOMY} = 2.72$$

## 3. Calculate generator fault current

$$Gen\_Fault := \frac{Gen\_VA}{\sqrt{3} \cdot Gen\_V \cdot X_{d_{subtrans}}}$$

$$Gen\_Fault = 824.305$$

$$Gen\_Fault_{sec} := \frac{Gen\_Fault}{CTR_X}$$

$$Gen\_Fault_{sec} = 20.608$$

## 4. Set Undervoltage 27 Element

The generator is designed to operate at minimum 95% of rated voltage.

$$\_27PPX1P := 0.88 \cdot VNOM$$

$$\_27PPX1P = 104.6 \text{ V}$$

$$\_27PPX1D := 2$$

$$\_27PPX1D = 2 \text{ sec}$$

$$\_27PPX2P := 0.50 \cdot VNOM$$

$$\_27PPX2P = 59.4 \text{ V}$$

$$\_27PPX2D := 0.16$$

$$\_27PPX2D = 0.16 \text{ sec}$$

## 5. Set Overvoltage Protection 59 Element

The generator is designed to operate continuously at 105% of rated voltage

$$\_59PP1P := 1.1 \cdot VNOM$$

$$\_59PP1P = 130.7 \quad \text{V}$$

$$\_59PPX1D := 1.0$$

$$\_59PPX1D = 1 \quad \text{sec}$$

$$\_59PP1P := 1.2 \cdot VNOM$$

$$\_59PP1P = 142.6 \quad \text{V}$$

$$\_59PPX1D := .16$$

$$\_59PPX1D = 0.16 \quad \text{sec}$$

## 6. Set Reverse Power Protection 32 Element

Set to existing ICW relay setting of 3.5%.

$$\_32P1P := 0.02 \quad [p.u.]$$

$$\_32P1P = 0.02$$

$$\_3PWRX1P_{PRI} := \_32P1P \cdot Gen\_VA$$

$$\_3PWRX1P_{PRI} = 2.352 \cdot 10^4$$

$$\_3PWRX1P := \frac{\_3PWRX1P_{PRI}}{(PTRX \cdot CTRX)}$$

$$\_3PWRX1P = 16.8$$

$$PWRX1D := 2 \quad [sec]$$

$$PWRX1D = 2$$

The element is internally blocked if voltages VAB or VBC are lower than 20V

**Table 12-2—Maximum motoring power for prime movers**

Steam turbine	3.0%
Water wheel turbine	0.2%
Gas turbine	50.0%
Diesel engine	25.0%

## 7. Set Loss-of-Field Protection 40 Element

Set according to IEEE C37.102, Appendix A and SEL guidance. Per SEL, "Typically, Zone 1 and Zone 2 are offset from the impedance plane origin by a value equal to one-half the machine transient reactance. Zone 1 is intended to operate with little time delay in the event of a loss-of-field under full load conditions. Zone 2 reaches further and operates with a longer time delay. Zone 2 is intended to trip for loss-of-field conditions that occur under light load conditions."

Zone 1 Setting Calculations      Method 1: Negative Offset

$$\_40Z1P := \frac{VNOM}{(\sqrt{3} \cdot I_{NOM})} \qquad \_40Z1P = 16.8$$

$$\_40XD1 := \frac{-Xd'_{sec}}{2} \qquad \_40XD1 = -2.8$$

$$\_40Z1D := 0.1 \qquad \_40Z1D = 0.1$$

Zone 2 Settings Calculations

$$\_40Z2P := Xd_{sec} \qquad \_40Z2P = 29.4$$

$$\_40XD2 := \frac{-Xd'_{sec}}{2} \qquad \_40XD2 = -2.8$$

$$\_40Z2D := 0.5 \qquad \_40Z2D = 0.5$$

40ZTC=NOT LOPX

## 8. 51C Phase Element Settings

Set to PG&E Distribution and Planning requested values.

51CP = 0.5

51CC = U5

51CTD = 2

51CRS = N

51VTC = 27PPX1

SV03 = 51C

SV03PU = 1.5 S

SV03DO = 0 S

## 9. Ground Element Settings

Set to existing BE1-59N relay settings.

EXT3EV0\_X:=VS

\_59GX1P:= 9.0 V

\_59GX1D:= "0.04" Sec

## 10. Set Frequency Protection 81 O/U Element

Set to existing relay settings.

81XTC=52A

\_81X1P:= 59.3    \_81X1D:= 0.16

\_81X2P:= 60.5    \_81X2D:= 0.16

## 11. Set Negative Sequence Overcurrent Protection 46 Element

Level 1, set to trip

Set according to IEEE C50.12 (Section 4.2.4) and SEL guidance.

$$\_46Q1P := 8 \quad [\%]$$

$$\_46Q1D := 30 \quad [\text{sec}]$$

Level 2, set to trip

Set according to SEL recommendations and IEEE C50.12 Table 2 below.  
(Generator MVA=1 MVA)

**Table 2—Short-time negative-sequence current capability**

Type of generator rotor cooling	Minimum generator short-time capability expressed in terms of $I^2t$
Indirectly cooled	30
Directly cooled up to 800 MVA	10
800 MVA to 1600 MVA	$10 - (0.00625)(\text{MVA} - 800)$
Above 1600 MVA	By agreement

$$\_46Q2P := 8 \quad [\%]$$

$$\_46Q2K := 10$$

$$\_46Q2K = 10$$

$$t_{op2} := \frac{\_46Q2K}{\left(\frac{\_46Q2P}{100}\right)^2}$$

Expected operating time  
at 8% unbalanced current  $t_{op2} = 1562.5 \quad [\text{sec}]$

$$t_{op2} := \frac{\_46Q2K}{\left(\frac{\_46Q2P \cdot 3}{100}\right)^2}$$

Expected operating time  
at 24% unbalanced current  $t_{op2} = 173.611 \quad [\text{sec}]$

$$t_{op2} := \frac{\_46Q2K}{\left(\frac{\_46Q2P \cdot 6}{100}\right)^2}$$

Expected operating time  
at 48% unbalanced current  $t_{op2} = 43.403 \quad [\text{sec}]$

## 12. Input / Output Assignment

### INPUTS

IN101 = 52a  
IN102 =  
IN301 =

### OUTPUTS

OUT101 = TRIP1 (5E1A) = SV03T OR SV06T OR 59GX1T OR 40Z1T OR 40Z2T OR 46Q2T  
OUT102 = 0  
OUT103 = **Test Output**  
OUT301 = 51VT  
OUT302 = 3PWRX1T  
OUT303 = 59GX1T  
OUT304 = 40Z1T OR 40Z2T  
OUT305 = 27PPY1T  
OUT306 = 46Q1T OR 46Q2T  
OUT307 =  
OUT308 =

### SELogic Variables and Timers

SV01T = PB01	LOCK BUTTON
SV02T = PB01 OR PB02 OR PB03 OR PB04	BUTTON DEBOUNCE TIME
SV03T = 51C	51C FIXED TIME DELAY
SV04T = LT04	TRIP SIGNAL
SV05T = (PB01 OR PB02 OR LT03 OR LT04) AND NOT SV05T	INITIATE FLASHING LED
SV06T = IN101 AND (27PPX1T OR 27PPX2T OR 59PPX1T OR 59PPX2T OR 81X1T OR 81X2T OR 3PWRX1T)	ENABLE TRIP WITH 52A