



## Humboldt Bay Municipal Water District Surge Tower Demolition Project Bid Addendum #2

The purpose of this Addendum is to modify the Contract Documents for the subject project. This Addendum shall become part of said Contract Documents.

**Bidders shall acknowledge receipt of this Addendum in their bid proposal.**

This Addendum addresses the following items and questions:

1. Has there been an asbestos or lead survey performed at the project site?
  - i) Yes, asbestos and lead survey reports were included with the bid documents. See Part 5 (Supporting Documents) of the Specifications.
2. Who is responsible for notifying PG&E of any applicable electrical disconnects?
  - i) There are no electrical connections that need to be interrupted, so it is not necessary to notify PG&E. Separations from existing power lines are assumed to be sufficient to safely perform the work, but if the Contractor does not agree, all onsite electrical is owned by the District. Disconnecting the site electrical would simply involve coordination with the District to de-energize the electrical lines of concern.
3. Is there a mix design for hydroseeding the project site?
  - i) The Contractor shall use the Caltrans standard mix for hydroseeding the project site.
4. When will the Notice to Proceed be issued for the project?
  - i) The intent is to award the project at the February 2019 HBMWD Board meeting and issue the Notice of Award in February. The intent is then to issue the Notice to Proceed in March 2019 after all contract documents are received from the selected Contractor.
5. May the Contractor use their own means and methods to dismantle the tower?
  - i) Yes. Demolition and Dewatering Note 2 on Sheet G-002 states that the Contractor may submit an alternative plan for approval by HBMWD and the Engineer. Additionally, General Note 3 on Sheet C-501 states that the Contractor may submit an alternate engineered demolition and lifting plan to allow for less or greater amounts of section removal, as opposed to removing one-third of a section at a time.

END OF ADDENDUM

February 1, 2019  
Date

  
Nathan Stevens, PE