



## Humboldt Bay Municipal Water District Collector 2 Rehabilitation Bid Addendum #1

The purpose of this Addendum is to modify the Contract Documents for the subject project. This Addendum shall become part of said Contract Documents.

**Bidders shall acknowledge receipt of this Addendum in their bid proposal.**

This Addendum addresses the following items and questions:

1. There is a point identified on C-103 that marks the transition between dewatering pipe to be provided by the Contractor and dewatering pipe to be provided by the District. The Contractor shall provide all piping, fittings, and other materials required to install the dewatering pipe upstream of this point, including piping within the collector caisson. The District will provide (Contractor shall install) all materials required for dewatering pipe installation that is downstream of this point, which includes Yelomine pipe, fittings, gate valves, gaskets, and bolt kits.
2. Specification 01 57 13 calls for erosion control. Is the contractor required to prepare a Stormwater Pollution Prevention Plan (SWPPP)?
  - i) The area of the percolation pond as shown on C-103 and C-104 shall be decreased by 2,600 square feet. This shall be accomplished by moving the eastern boundary of the pond westward by approximately 30 feet. All other design elements of the percolation pond remain unchanged. This change in pond area will result in less than one acre of soil being disturbed on the project, meaning that a SWPPP will not be required. The Contractor is still responsible for complying with the requirements provided in specification 01 57 13, including the requirement to provide an Erosion Control Plan for all disturbed areas, including the 70' x 75' area adjacent to Collector 2 as shown on C-101.
3. The Contractor shall be allowed to access the river bar from June 19, 2023 through October 20, 2023. Any conflicting dates provided in the contract documents shall be modified to be consistent with the timeline provided in this Addendum.
4. The contractor shall monitor the position and upward deviation of the lateral bore on a regular basis throughout the projection process and report their findings to the Engineer. Maximum allowable upward deviation shall be two lateral projection pipe diameters over the entire projected length of the lateral. The Contractor is relieved of any requirements related to measurement of horizontal or downward deviation of the lateral bore.
5. If the Contractor provides a locally rented diesel-powered generator, is there a requirement to provide an air quality permit?
  - i) It is anticipated that any air quality permitting required will be associated with the locally rented generator and that no additional air quality permitting effort will be required on behalf of the Contractor.
6. Specification 15 21 00 Section 3.6.A.5 shall be stricken in its entirety. The Contractor will not be required to provide or install a flow meter for performance flow testing. For flow tests, water will be run through the

District's system using District pumps, and associated flows will be captured from the District's SCADA data and provided to the Contractor for use in the Contractor's performance analysis.

END OF ADDENDUM

January 20, 2023

Date

A handwritten signature in black ink, appearing to read "Noble Ste", written over a horizontal line.

Signature